



LXI Clock Synchronization Extended Function

Revision 1.1

May 10, 2022

REFERENCE DOCUMENTS.....	3
REVISION HISTORY	4
1 OVERVIEW	5
1.1 INTRODUCTION	5
1.2 PURPOSE AND SCOPE OF THIS DOCUMENT.....	5
1.2.1 Purpose.....	5
1.2.2 Scope	6
1.3 DEFINITION OF TERMS.....	6
1.4 ADDITIONAL LXI CONFORMANCE REQUIREMENTS.....	7
1.4.1 Extended Functions.....	7
2 PHYSICAL SPECIFICATIONS.....	8
2.5 ELECTRICAL STANDARDS – STATUS INDICATORS	8
2.5.3 IEEE 1588 Clock Status Indicator.....	8
3 LXI DEVICE SYNCHRONIZATION AND EVENTS.....	11
3.2 LXI CLOCK SYNCHRONIZATION USING IEEE 1588	11
3.2.1 RULE – Implementation of IEEE 1588 Precision Time Protocol	11
3.2.2 Recommendation – Precision of LXI Device Clocks	11
3.2.3 Recommendation – Use of IEEE 1588 Boundary or Transparent.....	12
3.2.4 Recommendation – Traceability to UTC	12
3.2.5 RULE – Must Be Able to Set UTC Time	12
3.2.6 RULE – Must Be Able to Set UTC Time Manually.....	13
3.2.7 Recommendation – Include at Least One Highly Stable Clock.....	13
3.2.8 RULE – Communication of Time Must Use IEEE 1588 Time	13
3.2.9 Recommendation – Controller Capability to Set Time	14
3.2.10 RULE – Inclusion of IEEE 1588 Time-Based Triggers.....	14
3.2.11 Using Timestamps	14
3.2.12 RULE – Pulse-per-Second Output	14
3.2.13 LXI Clock Synchronization Web Interface Requirements	15

Notices

Notice of Rights All rights reserved. This document is the property of the LXI Consortium. It may be reproduced, unaltered, in whole or in part, provided the LXI copyright notice is retained on every document page.

Notice of Liability The information contained in this document is subject to change without notice. “Preliminary” releases are for specification development and proof-of-concept testing and may not reflect the final “Released” specification.

The LXI Consortium, Inc. makes no warranty of any kind with regard to this material, including but not limited to, the implied warranties of merchantability and fitness for a particular purpose. The LXI Consortium, Inc. shall not be liable for errors or omissions contained herein or for incidental or consequential damages in connection with the furnishing, performance, or use of this material.

LXI Standards Documents are developed within the LXI Consortium and LXI Technical Working Groups sponsored by the LXI Consortium Board of Directors. The LXI Consortium develops its standards through a consensus development process modeled after the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Consortium and serve without compensation. While the LXI Consortium administers the process and establishes rules to promote fairness in the consensus development process, the LXI Consortium does not exhaustively evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an LXI Consortium Standard is wholly voluntary. The LXI Consortium and its members disclaim liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other LXI Consortium Standard document.

The LXI Consortium does not warrant that the use of the material contained herein is free from patent infringement. LXI Consortium Standards documents are supplied “as is”. The existence of an LXI Consortium Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the LXI Consortium Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Users are cautioned to check to determine that they have the latest edition of any LXI Consortium Standard.

In publishing and making this document available, the LXI Consortium is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the LXI Consortium undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other LXI Consortium Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

This specification is the property of the LXI Consortium, a Delaware 501c3 corporation, for the use of its members.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of LXI Consortium, the Consortium will initiate action to prepare appropriate responses. Since LXI Consortium Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, LXI Consortium and the members of its working groups are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. Requests for interpretations of this standard may be sent to interpretations@LXIStandard.org using the form “*Request for Interpretation of an*

LXI Standard Document". This document plus a list of interpretations to this standard are found on the LXI Consortium's Web site: www.lxistandard.org .

Legal Issues, Trademarks, Patents, and Licensing Policies. These items are addressed specifically in the document "*LXI Consortium Trademark, Patent, and Licensing Policies*" found on the LXI Consortium's Web site: <http://www.lxistandard.org> .

Conformance The LXI Consortium draws attention to the document "*LXI Consortium Policy for Certifying Conformance to LXI Consortium Standards*" found on the LXI Consortium's Web site: <http://www.lxistandard.org> . That document specifies the procedures that must be followed to claim conformance with this standard.

Comments for Revision Comments for revision of LXI Consortium Standards are welcome from any interested party, regardless of membership affiliation with LXI Consortium. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards should be addressed to:

Executive Director
LXI Consortium
www.lxistandard.org
ExecDir@lxistandard.org


Revision History

<i>Revision</i>	<i>Description</i>
1.1 May 10, 2022	Added Rule 3.2.13.1 Added observation about newer versions of IEEE-1588 Added Rule 3.2.13.2 that was deleted in LXI 1.5 Moved pieces of section 9.6 from the Device Sepecification to 3.2.13.2 in this spec
1.0 Nov 8, 2016	Initial Release

1 Overview

1.1 Introduction

LXI Clock Synchronization inherits IEEE 1588-2008, a protocol used to synchronize real-time clocks with sub-microsecond accuracy in devices of a networked distributed system. This allows common timer events to be tied to absolute times for very precise triggering and synchronization. This also enables the correlation between instruments in order to aid monitoring and debugging.



IEEE 1588 specifies a Precision Time Protocol (PTP) that may be used to synchronize clocks in a Test and Measurement (T&M) system. When a T&M system implements PTP, each instrument, computer, or other controller in the system contains a clock. PTP allows synchronizing all these clocks and keeping them synchronized. PTP requires data communications between all devices; in T&M systems, this is typically implemented using Ethernet LAN. Other time synchronization methods have been used in T&M applications, including Network Time Protocol (NTP), Global Positioning Satellite (GPS) based systems, and hardwired distribution of reference oscillator signals. However, when compared with these alternatives, IEEE 1588-based systems provide more precise and accurate synchronization while offering the benefits of standard Ethernet LAN networking connections.

1.2 Purpose and Scope of this Document

1.2.1 Purpose

Each LXI Extended Function has its own document with unique section numbering that, if merged with the LXI Device Specification document, would produce a contiguous representation of the entire LXI Specification. Since all Extended Functions have some common requirements, this document will be the single reference to those requirements rather than repeating them in each separate document.

This document supplies the requirements for LXI conformance to the LXI Clock Synchronization Extended Function.

1.2.2 Scope

This document defines a common set of **RULES** and **RECOMMENDATIONS** for constructing a conformant LXI Device with one or more Extended Functions. Whenever possible these specifications use existing industry standards.

The original LXI Device Specification included both requirements for all LXI Devices and a number of Extended Functions in a single document. Common information remains in the LXI Device Specification and specific information related to the Extended Function moves to separate documents.

1.3 Definition of Terms

This document contains both normative and informative material. Unless otherwise stated the material in this document shall be considered normative.

NORMATIVE: Normative material shall be considered in determining whether an LXI Device is conformant to this standard. Any section or subsection designated as a **RULE** or **PERMISSION** is normative.

INFORMATIVE: Informative material is explanatory and is not considered in determining the conformance of an LXI Device. Any section or subsection designated as **RECOMMENDATION**, **SUGGESTION**, or **OBSERVATION** is informative. Unless otherwise noted examples are informative.

RULE: Rules **SHALL** be followed to ensure compatibility for LAN-based devices. A rule is characterized by the use of the words **SHALL** and **SHALL NOT**. These words are not used for any other purpose other than stating rules.

RECOMMENDATION: Recommendations consist of advice to implementers that will affect the usability of the final device. Discussions of particular hardware to enhance throughput would fall under a recommendation. These should be followed to avoid problems and to obtain optimum performance.

PERMISSION: Permissions are included to clarify the areas of the specification that are not specifically prohibited. Permissions reassure the reader that a certain approach is acceptable and will cause no problems. The word **MAY** is reserved for indicating permissions.

OBSERVATION: Observations spell out implications of rules and bring attention to things that might otherwise be overlooked. They also give the rationale behind certain rules, so that the reader understands why the rule must be followed. Any text that appears without heading should be considered as description of the specification.

1.4 Additional LXI Conformance Requirements

1.4.1 Extended Functions

1.4.1.1 General Description

The LXI Standard consists of the LXI Device Specification, required for all LXI Devices. In addition, it includes all optional Extended Functions.

LXI Extended Functions

Extended Functions come in the form of external documents. Each Extended Function document will have sections numbered as though they were part of the LXI Device Specification, but the documents are separate to simplify maintenance of the standard and to add new Extended Functions without altering the LXI Device Specification. The Guide to LXI Documentation identifies the Extended Function documents.

1.4.1.2 Conformance Requirements

The rules in this document define the conformance requirements for this Extended Function. In addition to the requirements for all LXI Devices found in the LXI Device Specification, an Extended Function may require conformance to another Extended Function. All these requirements are detailed in the following Rule.

1.4.1.2.5 RULE – LXI Clock Synchronization Conformance Requirements

The rules in this document define the conformance requirements for this Extended Function. In addition to the requirements for all LXI Devices found in the LXI Device Specification, there may be cases where an Extended Function requires conformance to another Extended Function. All requirements follow below:

LXI Device Specification Document:

- All LXI Devices shall conform to the rules found in Section 1.4 and all subsections
- Section 6.1.1 and 6.5 including all subsections
- Section 9.6 including all subsections
- Function element with the FunctionName attributes of “LXI Clock Synchronization” and version “1.0” in the LXIExtended Function element of the LXI identification document as described in section 10.2.5.

LXI Clock Synchronization (this document):

- Include all rules

2 Physical Specifications

The LXI Device Specification details the physical requirements for an LXI Device conformance. When adding the LXI Clock Synchronization, there are recommendations and observations added to the physical specification, as indicated below in Section 2.5.

2.5 Electrical Standards – Status Indicators

Section 2.5 of the LXI Device Specification contains the overall organization requirements and recommendations for positioning and labeling Status Indicators for an LXI Device. The first table in that section includes cases where the LXI Device supports LXI Clock Synchronization. Please refer to that Section for more information on the requirements. The sections below give more information on Recommendations and Observations when implementing the LXI Clock Synchronization Extended Function.

2.5.3 IEEE 1588 Clock Status Indicator

The IEEE 1588 Clock Status Indicator is designed to show both the status and the type of clock in the device. It is a multi-state device, in that it can flash at two different rates, and provide a steady or no indication depending on the type and status of the clock present.

2.5.3.1 Recommendation – IEEE 1588 Clock Status Indicator

An IEEE 1588 Clock Status Indicator should be provided on the front panel of the device.

Observation

This status indicator is specifically defined as a recommendation to enable easier device upgrades from a non-IEEE 1588 capable to an IEEE 1588 capable LXI Device without physical modifications to the front panel.

2.5.3.2 Recommendation – IEEE 1588 Clock Status Color

The IEEE 1588 Clock Status Indicator should be a single, bi-color LED (Red/Green) whose states are identified as follows:

State	PTP State of Port
Off	Not Slave, Not Master, and Not Faulty
On – Solid Green	Slave
On – Blinking Green once every second	Master but not Grandmaster
On – Blinking Green once every two seconds	Master and also Grandmaster
On – Solid Red	Faulty

Observation

The Red LED color is only utilized for fault states as defined in the IEEE 1588 specification. While a single green LED could be utilized, it becomes more difficult to easily differentiate between an Unsynchronized and a Fault state.

2.5.3.2.1 Permission – IEEE 1588 Clock Status Color

If an LXI Device’s design precludes the use of a bi-color LED, the use of a single Green colored LED is permitted. In this situation, the IEEE 1588 Clock states should be interpreted as follows:

State	PTP State of Port
Off	Not Slave and Not Master
On – Solid Green	Slave
On – Blinking Green once every second	Master but not Grandmaster
On – Blinking Green once every two	Master and also Grandmaster

2.5.3.3 Recommendation – IEEE 1588 Clock Status Indicator Location

The IEEE 1588 Clock Status Indicator should be placed on the lower left hand corner of the device, next to and to the right of the LAN Status Indicator.

2.5.3.4 Recommendation – IEEE 1588 Clock Status Indicator Orientation

Orient the Status Indicators horizontally oriented as follows.

From left to right: Power Indicator, then LAN Indicator, then the IEEE 1588 indicator.

Observation

The status indicators are ordered in the LXI Device turn-on sequence: first, enable power; second, acquire LAN IP Configuration; and third, acquire the IEEE 1588 clock. This orientation allows the user to observe the turn-on sequence and to easily determine which stage may have failed.

2.5.3.4.1 Permission – IEEE 1588 Clock Status Indicator Orientation

It is permitted for the Status Indicators to be vertically oriented as follows. From bottom to top: Power Indicator, then LAN Indicator, then IEEE 1588 indicator.

Observation

The status indicators are ordered in the LXI Device turn-on sequence: first, enable power; second, acquire LAN IP Configuration; and third, acquire the IEEE 1588 clock. This orientation allows the user to observe the turn-on sequence and to easily determine which stage may have failed.

2.5.3.4.2 Permission – LXI Devices with a Front Panel Display

For devices with a front panel display, the equivalent indications may be presented in a different manner consistent with the design and capabilities of the front panel.

The use of symbols on a display, instead of LED status indicators, is permitted. Such indicators do not have to be permanently visible but could be accessed via some display navigation method.

2.5.3.5 Recommendation – IEEE 1588 Clock Status Indicator Label

Label the IEEE 1588 Clock Status indicator “1588”.

2.5.3.5.1 Permission - Application Specific Status Indicators

Additional application specific status indicators, beyond the basic ones already outlined, are permitted.

3 LXI Device Synchronization and Events

This section specifies the use of IEEE 1588 to provide a system-wide common precision timebase created by including a synchronized real-time clock in each participating LXI Device. This timebase may be used for a variety of functions including:

- Timestamping data to expedite post acquisition analysis and ordering
- Generating LXI Events for precise triggering and synchronization within an LXI Device or system-wide
- Generating LXI Event Logs to allow total ordering of LXI Events occurring in all parts of a system
- Generating synchronous signals in multiple LXI Devices.

3.2 LXI Clock Synchronization Using IEEE 1588

3.2.1 RULE – Implementation of IEEE 1588 Precision Time Protocol

Each LXI Device that implements IEEE 1588 shall provide functionality fully conformant to the standard IEEE 1588-2008 and the LXI 1588 Profile.

Observation– New versions of IEEE 1588

IEEE 1588-2019 (Version 2.1) is now available and is backwards compatible with IEEE 1588-2008 as long as the features and options of the LXI 1588 profile are adhered to.

IEEE-1588-2019 has many new features such as: Fibre connections, real-time Ethernet, security and more accurate clock synchronization.

LXI, at this time, is not requiring that LXI devices move to IEEE 1588-2019. LXI is monitoring the standards body for IEEE-1588 and especially their work on cyber-security.

LXI is not preventing a LXI device implementing IEEE 1588-2019 as long as they abide by the LXI 1588 profile.

Observation– Older versions of IEEE 1588

LXI Standard Versions 1.3 and later of the specification require LXI Devices to support the IEEE 1588-2008 or later versions of the IEEE 1588 standard. LXI Standard Versions 1.2 and earlier of the specification require LXI Devices to support the earlier version, IEEE 1588-2002. Recommendations for managing the incompatibilities between versions of IEEE 1588 are contained in a white paper “Recommendations for LXI systems containing devices supporting different versions of IEEE 1588”.

3.2.2 Recommendation – Precision of LXI Device Clocks

IEEE 1588 should be implemented to a precision adequate for the timing performance of the device. It is further recommended that LXI Devices implement time to a precision of 40 nanoseconds or better.

Observation– Software Implementations Have Less Precision

It is possible to implement IEEE 1588 functionality using only software. However, hardware implementations are preferred and will be necessary to achieve a time precision of 40 nanoseconds.

3.2.2.1 Permission – Software implementation in controllers

Software implementations of IEEE 1588 may be used in controllers but is discouraged in LXI Devices.

Observation– All LXI Devices in a System Should Have Appropriate Precision

System integrators making use of time-based control of an entire system must coordinate the time behavior of each LXI Device. The ability to fine-tune this coordination depends directly on the overall precision of the time base. The inclusion of a single LXI Device with poor precision, say 10 ms, will severely limit system integrators.

3.2.3 Recommendation – Use of IEEE 1588 Boundary or Transparent Clocks

The timing precision of a system of LXI Devices will be limited by, among other things, the quality of the LAN bridges in the system. The use of LAN bridges designed as IEEE 1588 boundary or transparent clocks is highly recommended.

Observation– Use of Low-Latency Switch

If a boundary or transparent clock is not available, the use of a LAN switch that offers low latency for UDP packets may yield acceptable timing precision.

3.2.4 Recommendation – Traceability to UTC

The time base of an LXI system should be traceable to UTC.

Observation – PTP Timescale

Traceability to UTC is achieved by implementing the timescale PTP defined in IEEE 1588.

3.2.5 RULE – Must Be Able to Set UTC Time

Any LXI Device implementing IEEE 1588 functionality shall be capable of being made traceable to UTC in the event that it is selected as the grandmaster clock by the IEEE 1588 protocol.

Observation– Setting time to UTC

Rule 3.2.5 may be implemented by designing the device to be an IEEE 1588 clock Class 6 device, by virtue of rule 3.2.6, or by having the time and time properties settable from the device sync web page.

3.2.6 **RULE – Must Be Able to Set UTC Time Manually**

Traceability to UTC shall be, at a minimum, available by the use of IEEE 1588 management messages with managementId values of: TIME, CLOCK_ACCURACY, UTC_PROPERTIES, TRACEABILITY_PROPERTIES, and TIMESCALE_PROPERTIES.

3.2.6.1 **Recommendation – Battery Backup for Clocks**

It is recommended that devices capable of being a grandmaster clock provide battery backup time-of-day clocks to provide holdover in the event of power failure.

Observation– Unsafe to Make Large Time Corrections During Operation

Making large changes to the LXI time base during system operation may result in unintended failures. It may take some time (up to a minute or so) for clocks to re-synchronize. (This is especially true if the IEEE 1588 system is shut down or reset.) It is expected that time base updates will have to be manually initiated by the operator during a "safe" period. However, some applications may be able to recover dynamically.

3.2.7 **Recommendation – Include at Least One Highly Stable Clock**

All LXI systems should include at least one device specifically designed to provide a very stable PTP time base.

Observation– Ability To Identify Grand Master Clock

Recommendation 3.2.7 allows system integrators to explicitly control the identity of the grandmaster and therefore better implement the requirements listed above.

3.2.8 **RULE – Communication of Time Must Use IEEE 1588 Time Base**

All time references communicated to or from LXI Devices in an LXI system shall be based on the system-wide IEEE 1588 timescale established by the IEEE 1588 clocks in each device. Translation between the IEEE 1588 time base and UTC in an LXI Device shall only occur at the interface to another subsystem external to the portion of the system operating based wholly or in part on time (e.g. a user interface or a database). All LXI Devices required to make this translation shall use the currentUtcOffset information distributed by the IEEE 1588 protocol.

Observation– Absolute Oscillator Accuracy

The IEEE 1588 standard requires an absolute accuracy of 0.01% for the oscillator driving the IEEE 1588 clock. This type of specification is necessary to limit the maximum frequency adjustment range of a clock to ensure that it can be synchronized to any master. Implementers may wish to use oscillators with better accuracy specifications but less tracking range. If they do so, they should ensure that the rest of the implementation is also of sufficiently high accuracy that the IEEE 1588 clock characterization parameters will ensure that (1) it will be selected as the master clock, or (2) any other system device that can be selected as a master clock (based on clock characterization) also has the same or better accuracy specifications.

Observation– Handling Leap Seconds

The IEEE 1588 protocol provides the leap second information needed to convert between the IEEE 1588 epoch and UTC, so any node with an IEEE 1588 clock will

have the data needed to translate between the two systems, PROVIDED the IEEE 1588 grandmaster inserts the information into the Announce packets. This is easy, if the ultimate time source is GPS (since leap second information is available from GPS), but not so easy (but still possible) for NTP, and even less so if the system time is set by hand.

Observation– Translating Between Different Time Bases

There are a number of different representations of time (e.g. the IEEE 1588 time base and UTC) that are widely used in the industry. These systems have different references for time=0, and they treat leap seconds with greater or lesser rigor. Because of this, translating between different time bases is not necessarily a straightforward calculation. The IEEE 1588 time base does not exhibit discontinuous behavior during leap second corrections, but this is not true of all other systems. As a result, computing a time interval by subtracting two IEEE 1588-based time values will always be correct (even if the time interval includes a leap second,) but the same cannot be said if, for example, NTP is used.

While this issue will be unimportant for many test system applications, some systems will be synchronized to outside time sources such as GPS. In those cases, care must be taken to account for leap seconds properly.

3.2.9 Recommendation – Controller Capability to Set Time

All LXI controllers should be capable of setting the IEEE 1588 time in the grandmaster via the use of IEEE 1588 management messages with managementId values of: TIME, CLOCK_ACCURACY, UTC_PROPERTIES, TRACEABILITY_PROPERTIES, and TIMESCALE_PROPERTIES.

3.2.10 RULE – Inclusion of IEEE 1588 Time-Based Triggers

LXI Devices containing triggerable functions or events and which implement IEEE 1588 shall include one or more time-based triggers. This is necessary for implementation of autonomous time-based event coordination in the LXI Device.

Observation– Implement Time-Based Triggers in Hardware

While time-based triggers can be implemented in software, hardware-based time triggers based on the IEEE 1588 clock are necessary for high-precision timing. Implementers should carefully consider the applications in which their LXI Devices will be used to ensure that time-based triggers are sufficiently accurate.

3.2.11 UsingTimestamps

Note that LXI Devices generating timestamps based on an IEEE 1588 need to follow requirements in the *LXI Timestamped Data Extended Function*.

3.2.12 RULE – Pulse-per-Second Output

A pulse-per-second output shall be available on all LXI Devices implementing IEEE 1588. The mechanical and electrical specifications of this output shall be vendor-defined, but the output shall generate a rising edge synchronous with the second's transitions of the IEEE 1588 clock.

This pulse-per-second output is intended to be compared with corresponding outputs of the other clocks in the system to verify synchronization performance. The test point does not need to be available externally, although it can be brought to an external point if desired (for instance, by

configuring the LXI Wired Trigger Bus to carry the signal).

3.2.13 LXI Clock Synchronization Web Interface Requirements

3.2.13.1 RULE – Show PTP Time on LXI Welcome Web Page

Devices implementing the LXI Clock Synchronization extended function shall add the IEEE-1588 PTP time to the list of items to be shown on the LXI Welcome page. See Rule 9.2, in the LXI Device Specification, for further information.

3.2.13.2 RULE – Show IEEE-1588 Parameters on LXI Sync Configuration Web Page


The following IEEE-1588 parameters need to be shown on the LXI Sync Configuration Web Page defined in section 9.6

Item	Value
IEEE 1588 Parameters:	
Current grandmaster clock	Hostname, IP address, or MAC address
Parent clock	Hostname, IP address, or MAC address
State	Master, Slave, Faulty, Disabled, Passive, Uncalibrated, Other (Initializing, Listening, Pre-master)
Current PTP time	Seconds since 0 hours, 1 January 1970 TAI (represented as a string of the form “seconds.fractional seconds”)
Current local time (if available)	Date/time
Current grandmaster traceability to UTC	The string corresponding to the value of the timeSource field of the Announce message as defined in Table 7 of IEEE 1588, e.g. GPS, NTP, HAND_SET or ATOM...
Current observed variance of parent clock	In (nanoseconds) ²
Current source of time	String representing clock in use (e.g. IEEE-1588 PTP)
IEEE 1588 Domain	The integer, domainNumber, as defined by IEEE 1588.
IEEE 1588 Version	The integer, versionNumber, as defined by IEEE 1588, e.g. 2 for IEEE 1588-2008.

Observation

Depending on the implementation, the value of the “Current PTP time” can be obtained by

- (1) directly reading the IEEE 1588 clock and translating into the display format or
- (2) using the timestamp received in an IEEE 1588 management message with managementID = Time, and translating into the display format.



Observation

Devices that do not compute the “Current observed variance of parent” parameter shall display “Unavailable” (without quotes) as the parameter value.

Observation

Vendor is permitted to also place Current Time and Current Source on Home Web Page.